



QUALITY AUDITING INSTITUTE

#16-211 Schoolhouse St, Coquitlam, B.C. V3K 4X9

Tel: (604) 527-8378 Fax: (604) 527-8368

Website Address: www.qai.org

E-mail: Info@qai.org

December 17, 2010

Dayliter Skylights
5492 275th street
Langley BC
Canada, V4W 3X7

SUBJECT: In-Lab Testing - Dayliter Roof Door

Dear Mr. Corr,

This letter confirms that Quality Auditing Institute (QAI) has completed In-Lab Testing of the Dayliter Roof Door to the requirements of AAMA/WDMA/CSA 101/IS2/A440-08 standard. The product was tested on December 17, 2010 to Performance Class "R" with the following results:

Product	Standard	Test	Results	
			Required Achieved	Pass/Fail
Dayliter Roof Door	ASTM E283	Air Leakage	A2	Pass
	ASTM E331	Water Penetration	730 Pa	Pass
	ASTM E330	Deflection	960 Pa	Pass
	ASTM E330	Blowout	1920 Pa	Pass

Full results are reported in QAI Test Report T691-5 dated November 16, 2010. The Roof Door has met the requirements of the AAMA/WDMA/CSA 101/IS2/A440-08 when tested to Performance Class "R". By Testing to this standard, the Dayliter Roof Door is also in compliance with the performance requirements of the CAN/CGSB 63.14-M89 currently referenced in the 2006 BC Building Code.

Should you have any questions, please do not hesitate to contact Quality Auditing Institute Ltd. at 604-527-8378.

Regards,
Quality Auditing Institute Ltd

Kevin Saito, Division Manager
604-527-8378
ksaito@qai.org